

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that *some* constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More Information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the *Safe Drinking Water Hotline (800-426-4791)*.

Dorchester County Water Authority
PO Box 1565
Summerville, SC 29484



Dorchester County Water Authority

2008 Annual Drinking Water Quality Report

If you have any questions about this report or your water utility, please contact Richie Murdaugh at (843)875-0296 ext. 227

If you would like to learn more about your water provider, please attend any of our regularly scheduled meetings. They are held at 5:30 pm on the second Monday night of each month in our office located at 967 Orangeburg Road.

2008 Reevesville System #1820002

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. The water in our system is provided by wells. If you have any questions about this report or concerning your water utility, please contact Richie Murdaugh. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month 5:30 pm at DCWA office, 967 Orangeburg Road, Summerville SC. Our Source Water Assessment Plan is available for your review at www.scdhec.gov/water/html/srcwtr.html. If you do not have internet access, please contact Richie Murdaugh, at (843)875-0296 ext. 227 to make arrangements to review this document or to ask other questions.

Dorchester County Water Authority routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2008. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of material used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Reevesville—Test Results

Contaminant	Violation	Level	Unit	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Fluoride 2008	N	0.35	PPM	4	4	Erosion of natural deposits, water additive which promotes strong teeth; discharge from fertilizer
Copper, Free 2008	N	90th % = 0.023 0-AL ND—0.029	PPM	1.3	AL = 1.3 PPM	Corrosion of household plumbing. Erosion of natural deposits.
Disinfectants and Disinfection By-Products						
HAAS (Haloacetic Acids) 2008	N	RAA 16 (Range 10-24)	PPB	0	60 PPB	By-product of drinking water disinfection.
TTHM (Total trihalomethanes) 2008	N	RAA 38 (Range 20-50)	PPB	0	80 PPB	By-product of drinking water chlorination.
Chlorine 2008	N	HQA 1.73 (Range .27-1.99)	PPM	MRDL=4	MRDLG=4	Water additive used to control microbes.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) -laboratory analysis indicates that the constituent is not present.

Parts per million (PPM) or Milligrams per liter(mg/l) one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (PPB) or Micrograms per liter-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - (AL) The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.